



**District Level Water Analysis Laboratory,**  
**U.P. Jal Nigam (Rural), Azamgarh**  
 Rampur Satbhariya Water Supply Campus,  
 District- Azamgarh-276001

Lab ID: T-5716

Rept. No. UPJNAZ/FEB/138

Date: 07/02/2025

Page No. 1/2

### Technical Data of Analysis

S.No.	Analysed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Unit	Permissible Unit	
1	Conductivity	224.60	mS/cm	NA	NA	IS 3025 (Part 14) : 2017
2	Sulphate	1.50	mg/l	250.00	400.00	IS 3025 (Part 24) : 2022
3	Nitrate	1.24	mg/l	45.00	No relaxation	IS 3025 (Part 34) : 2019
4	Iron	0.00	mg/l	1.00	No relaxation	IS 3025 (Part 53) : 2019
5	Arsenic	0.00	mg/l	0.01	No relaxation	IS 3025 (Part 37) : 2022
6	Fluoride	0.00	mg/l	1.00	1.50	IS 3025 (Part 60) : 2019

- Note:-**
1. This Certificate refers only to the particular sample(s) submitted for testing.
  2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained.
  3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
  4. Sample will be stored up to 7 days (in case of non-perishable items only) from the date of issue of test reports unless otherwise specified.


  
 (Sushil Kumar)  
 D.E.O.  
 Prepared By

  
 (Radheshyam Rawat)  
 Quality Manager  
 Authorized Signatory  
 Mobile No. 9825342347

Lab E-Mail ID :- rnikalalaxy@gmail.com

End of Test Report

  
**Principal**  
 Shivam Children Academy  
 Naurasiya, Tarwan, Azamgarh

  
**Manager**  
 Shivam Children Academy  
 Naurasiya, Tarwan, Azamgarh